

Edna Ariane Peñaloza CONSTRUCTORA Y EDIFICADORA GIA+A	Architectural Submittal : Elevator TRANSMISIÓN	18/11/2021 GIA-TRN-000364
Fabian Rosas Reyes CONSTRUCTORA Y EDIFICADORA GIA+A	Re: Architectural Submittal : Elevator CORRESPONDENCIA GENERAL	26/11/2021 GIA-GNC-000146
Stephanie Salas - VIAWORK GLOBAL MX IKANO	Re: Architectural Submittal : Elevator CORRESPONDENCIA GENERAL	26/11/2021 IKN-GNC-001872
Fabian Rosas Reyes CONSTRUCTORA Y EDIFICADORA GIA+A	Re: Architectural Submittal : Elevator CORRESPONDENCIA GENERAL	27/11/2021 GIA-GNC-000149
Luca Maugeri - VIAWORK GLOBAL MX IKANO	Re: Architectural Submittal : Elevator CORRESPONDENCIA GENERAL	27/11/2021 IKN-GNC-001879
Fabian Rosas Reyes CONSTRUCTORA Y EDIFICADORA GIA+A	Re: Architectural Submittal : Elevator CORRESPONDENCIA GENERAL	27/11/2021 GIA-GNC-000150
Luca Maugeri - VIAWORK GLOBAL MX IKANO	Re: Architectural Submittal : Elevator CORRESPONDENCIA GENERAL	8:27 IKN-GNC-001885
Stephanie Salas - VIAWORK GLOBAL MX IKANO	Architectural Submittal : Elevator - reply TRANSMISIÓN	11:01 IKN-TRN-000695

IKEA Puebla
Plaza Vía San Ángel
Vía Atlíxcayotl 1504
Col. Reserva Territorial Atlíxcáyotl
Puebla
Puebla Mexico



TIPO DE CORREO
Transmisión

NÚMERO DE CORREO
IKN-TRN-000695

NÚMERO DE REFERENCIA
GIA-TRN-000364

Architectural Submittal : Elevator - reply

De Stephanie Salas - VIAWORK GLOBAL MX - IKANO

Para Srta. Edna Ariane Peñaloza - Constructora y Edificadora GIA+A

CC (8) BORIS OLGUIN RIBERA - Constructora y Edificadora GIA+A (y 7 más...)

Enviados lunes 29 de noviembre de 2021 9:01:51 AM PST (GMT -08:00)

Motivo Issued for Review

Estatus N/A

DOCUMENTOS ADJUNTOS (1)

Archivo	No. de documento	Revisión	Fecha de la revisión	Título	Estatus
	652-GIA-AR-DAT-0049	02	18-nov-2021	ELEVATOR	Aprobado con comentarios

MENSAJE

Workflow Review History

The attached documents have completed the "09. All Consultants Review" workflow with the following results :

Doc No	Step	Participant	Review Outcome	Comments
652-GIA-AR-DAT-0049	Quality Review	S Salas - VIAWORK GLOBAL MX	Approved	
	Global Review	E Lopez	Approved	
	Takasago Review	O Yoshida	Approved with Comments	Is it only 1 phase 110V 1.5kW 18.5A? When it is 1 phase 127V, is it acceptable 15A? Which is ground system only main feeder cable with ground or is it required individual ground? Please follow low voltage system at site meeting.
	STI Review	U Alonso	Approved with Comments	Due to the lift is smaller, into the shaft there is a space with not use... It's necessary place a wall? or we need a flashing? (See comment into the PDF). Consider to place and articulated ramp (See comment into the PDF)
	WSP Review	S Lopez	Approved with Comments	PROPORCIONAR DETALLES DE PLACAS Y ANCLAJES CON CARGA POR ANCLAJE, LA PROFUNDIDAD DE LOS ANCLAJES NO DEBERA SUPERAR LA CAPA DE COMPRESION DEL SPANCETE
	Three Review	B Garza	Approved with Comments	As per IKEA Std 09-0100.Lifts: Maximum noise level from any part of the lift machines shall be 60 dBA, a Please add noise specifications. The supplier of lift shall provide information regarding life expectancy for components involved, normal maintenance cost and energy costs sufficient to produce a calculation for a Life Cycle Cost analysis. Finishes do not match section's 2.5 finishes Please add warranty information. On materials a 5 year warranty is required. On mechanical wearing parts that depend on the usage an agreement shall be made, in conjunction with maintenance, to obtain at least 3 year supplier's warranty as a standard.
	Review & Response	L Maugeri - VIAWORK GLOBAL MX	Approved with Comments	GIA to consider Consultant Comments GIA to invite Supplier in the Construction meeting to close out/clarify comments GIA Swing door proposed dangerous for coworker - safety mesure from supplier need to be part of the specs for further assessment - IKEA request mandatory

Stephanie Salas Valdez

Assistant Project Manager/Document Controller at **Via Work Global Mexico**

From: E Peñaloza

Sent: 11/18/21 12:07:35 PM CST (GMT -06:00)

To: Luca Maugeri - VIAWORK GLOBAL MX, Alberto Rodriguez - VIAWORK GLOBAL MX, Stephanie Salas - VIAWORK GLOBAL MX

Cc: JAVIER LOPEZ PAZ, Lesly Liliana Meza, BORIS OLGUIN RIBERA, Anaid Rabanales Damian

Mail Number: GIA-TRN-000364

Subject: Architectural Submittal : Elevator

Cantidad	Descripción	Notas

C.c para

--	--	--	--	--

Nombre de compañía	Nombre del contacto	Número de fax	Copias	Notas

Solicitado Por

Recibido por:

Firmado:

(Nombre y firma)

(Nombre y firma)